

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244614
Address: 3437 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Kyle Beard	Passed	Tuesday, October 08, 2024

Informational:

1	Miscellaneous Correction	Footing was passed by a third party. Piers were not present in the footing report. Full erosion control measures were not in place at the time of third party footing inspection because gravel is not on site or between the foundation and the street.
---	--------------------------	---

Comments: