

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241046

Address: 1427 SW WINTHROP TER, LEES SUMMIT, MO 64081
1425 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Failed	Tuesday, October 08, 2024

Corrective Action Required:

1	MISC	-Provide UL wall design with cement board used for fire-rated wall assembly -In unit 1427, replace damaged GB above shower
---	------	---

**Alex probably inspected the attic separation

**Provide 1 hr separation in basement

Comments: