

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241766
Address: 2066 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Wednesday, October 09, 2024

Corrective Action Required:

1	Misc	-Use listed conduit at covered deck (PEX IS NOT APPROVED CONDUIT) **OK TO INSULATE. DO NOT COVER INSPECTION ITEMS
---	------	--

Comments: