

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20243082  
Address: 1020 NW PRYOR RD, Unit:C, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	Robb Popp	Partial	Wednesday, October 09, 2024

Corrective Action Required:

1	Miscellaneous Correction	10' 14x18 section inspected on ground for rooftop penetration -Light test for grease duct complete
---	-----------------------------	---

**Comments:**