

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241618
Address: 1801 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Wednesday, October 09, 2024

Corrective Action Required:

2	Miscellaneous Correction	1801 SW Hightown. Occupancy No light receptacle at the bottom of the stairs to illuminate the stairs
---	--------------------------	---

Comments: