

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242853  
Address: 1901 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Failed	Wednesday, October 09, 2024

Corrective Action Required:  
2      Miscellaneous      1901 SW Hightown      Occupancy (2)  
         Correction

Sod, sump pump extension and splash pads are not installed  
Seal all exterior penetrations  
Ground rod is not to code length from meter base

**Comments:**