

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242598
Address: 3808 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Wednesday, August 28, 2024

Corrective Action Required:

1	Miscellaneous Correction	Exterior garage portal sheeting in not nailed at blocking between studs (pages S530 in your plans)
---	--------------------------	--

This was scheduled for a exterior garage portal inspection only

Comments: