



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113001, Building Permit - Commercial
Address: 1499 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Passed	Wednesday, October 19, 2011

Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Wednesday, October 19, 2011
--	--------------	--------	-----------------------------

Corrective Action Required
1 MISC

1. INSTAL SIDE GRAB BAR AT MAX 12" FROM REAR WALL.
 2. INSTALL LOAD SIGNS AS PER F.D.
 3. INSTAL WHEEL CHAIR LIFT-BLOCK OPENING FROM FLOOR TO 42". FOR TCO.
 4. LABEL MAIN GAS METER (1499)
 5. EXIT SIGNS AS PER F.D. LOCATION.
- OK FOR TCO WHEN #1,3 ARE COMPLETE.

Above Ceiling Inspection	Mark Harding	Passed	Wednesday, October 19, 2011
---------------------------------	--------------	--------	-----------------------------

Gas Service Inspection - Commercial	Mark Harding	Passed	Wednesday, October 19, 2011
--	--------------	--------	-----------------------------

Comments: