

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20243082
Address: 1020 NW PRYOR RD, Unit:C, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Robb Popp	Partial	Thursday, October 10, 2024

Corrective Action Required:

1	Miscellaneous Correction	10' 14x18 section inspected on ground for rooftop penetration -Light test for grease duct complete -First layer wrap ok
---	-----------------------------	---

Comments: