

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244650
Address: 1021 SW REDBUCK CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Shawn Hoffman	Failed	Thursday, October 10, 2024

Corrective Action Required:

1	R506.2 Site preparation	CONCRETE FLOORS (ON GROUND). The area within the foundation walls shall have all vegetation, top soil and foreign material removed.
---	-------------------------	---

Comments: