

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242214  
Address: 3816 SW RAVENGATE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector: | Outcome:          | Date:                      |
|---|------------|-------------------|----------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Kyle Beard | Ready for Temp CO | Thursday, October 10, 2024 |

Corrective Action Required:

|   |                          |  |
|---|--------------------------|--|
| 2 | Miscellaneous Correction | 3816 SW Ravengate. Occupancy (2)<br><br>Sump pump extension is not installed<br>Sod and splash pads are not installed<br><br>Passed for TCO only |
|---|--------------------------|--|

**Comments:**