CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244826

Address: 1421 SW WINTHROP TER, LEES SUMMIT, MO 640811419 SW WINTHROP TER, LEES SUMMIT, MO

64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Footing Inspection - Residential Kyle Beard Failed Thursday, October 10,

2024

Corrective Action Required:

1 Miscellaneous

Correction - Demising wall footing plans call for 3 rebar and 24 inches wide of footing

the entire length from east to west. Demising wall footing is not to plans on

site

Comments: