

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242857

Address: 1420 SW WINTHROP TER, LEES SUMMIT, MO 640811418 SW WINTHROP TER, LEES SUMMIT, MO  
64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Kyle Beard	Failed	Thursday, October 10, 2024

Corrective Action Required:

2	Miscellaneous Correction	Fully seat sheet rock screws up against the rafter at demising wall on both sides
---	-----------------------------	---

**Comments:**