

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242368
Address: 1629 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Friday, October 11, 2024

Corrective Action Required:

1	Misc	-fire block hvac chase to ceiling space in garage -4 2x4 at bed 5 entry to plans -fire block kitchen/garage wall to ceiling space -secure gas line at fireplace -seal penetrations in vertical to horizontal fire blocking every 10' -connect ufer to main point of disconnect --address holes drilled to close to one another in floor joists above sub panel in basement
---	------	--

Comments: