

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241491  
Address: 4005 NE APPLE GROVE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Friday, October 11, 2024

Corrective Action Required:

1	Misc	-Complete installing fireplace **complete soffit. Provide min 1" clearance around the fireplace vent. Min 3" above the vent.
		-Nail corner studs 16d@12" oc or equivalent nailing

**Comments:**