

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240573

Address: 3737 SW KNOXVILLE CT, LEES SUMMIT, MO 640823735 SW KNOXVILLE CT, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Friday, October 11, 2024

Corrective Action Required:

2	Miscellaneous Correction	3735 and 3737 SW Knoxville. Occupancy (2)
---	--------------------------	---

3737
uncover water meter lid

Both units
Deck is missing a joist hanger
Deck joist hanger is missing
Tighten 1/2 inch bolts on cedar beam to rim joist connection

Comments: