

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

| | | | |
|--------------------|--|---------------------------|------------------|
| Permit No: | PRCOM20114124 | Date: | October 20, 2011 |
| Project Title: | MEN'S WEARHOUSE | Applicant: | |
| Location: | 1704 NW CHIPMAN RD. LEES SUMMIT, MO 64081 | National Fire Suppression | |
| Type of Work: | Sprinkler Alteration | 501 Sunshine Road | |
| Occupancy Group: | M | Kansas City, KS 66115 | |
| Description: | MEN'S WEARHOUSE | (913) 321-9208 | |
| INTERIOR REMODEL | | | |
| Construction Type: | Type IIB (Unprotected) | | |
| Map Page: | 194D | | |

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans recieved October 17, 2011.

2. 2006 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

The existing system shall have documentation of a current annual inspection. Verified at inspection.

3. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

A visual inspection will be completed at occupancy inspection.