CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245260

Address: 3517 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Kyle Beard Failed Monday, October 14,

Residential 2024

Corrective Action Required:

1 Miscellaneous 3517 SE Corbin. All rough Correction Fire block all holes in top plate

Vertically fire block every 10 feet on center along exterior walls

Lower smoke/CO detector to ceiling height

Fire block around ibeams

Comments: