



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20242672	Date:	October 14, 2024
Project Title:	MAGIC NOODLE 2	Applicant:	
Location:			
1020 NW PRYOR RD, Unit:E, LEES SUMMIT, MO 64081		AEGIS FIRE PROTECTION LLC	
Type of Work:		11936 W 119TH ST #262	
Occupancy Group:	A-2	OVERLAND PARK, KS 66213	
Description:	MAGIC NOODLE 2 - TENANT FINISH	Primary: (913) 825-0343	
FOR RESTAURANT			
Construction Type:	Type VB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Craig Hill

Released for Construction

1. 2018 IFC 903.4.2- Alarms. Approved audible and visual devices shall be connected to every automatic sprinkler system. Such sprinkler water-flow alarm devices shall be activated by water flow equivalent to the flow of a single sprinkler of the smallest orifice size installed in the system. Listed alarm notification devices shall be provided on the exterior and interior of the building in an approved location. Where a fire alarm system is installed, actuation of the automatic sprinkler system shall actuate the building fire alarm system.

2. 2018 IFC 904.4.2- Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

Call (816) 969-1300 to schedule alarm test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.