

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236080
Address: 2354 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Partial	Monday, October 14, 2024

Corrective Action Required:

1	Misc	10-11-24 Dustin, Dw is formed and compacted. Gravel depth is not deep enough through approach, (less then 4 in) need to correct before can pour. Will need to be recalled in for pre pour inspection before poured.
		10-14-24 Dustin A, DW recalled in, depths have been corrected, Approved to pour

Comments: