

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242187
Address: 1613 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Failed	Monday, October 14, 2024

Corrective Action Required:

1	Misc	- REMOVE TRASH AND DEBRIS FROM LOT
---	------	------------------------------------

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	10-14-24 Dustin A, Straw waddle has been damaged or removed in spots and needs to be fixed. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	--

Comments: