

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230570
Address: 1950 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Surface	Bobby Richest	Passed	Tuesday, October 15, 2024

Informational:

1 Misc

7-29-24 BR Contactor (JE Dunn) poured 5" asphalt base course TYPE-1 on south and north side of parking lot.

10-11-24 BR Contractor (JE Dunn) poured 2" asphalt surface 100% on parking lot. Ready for striping parking lot.

10-15-24 BR Contractor (JE Dunn) stiped 100% of parking lot and signs installed.

Comments: