

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244457
Address: 1020 NW PRYOR RD, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Failed	Tuesday, October 15, 2024

Corrective Action Required:

1	Misc	-Secure Pex lines 48" vertical max spacing-not done -Protect all DWV within 1.25"-missing at bottom track 2 locations **OK TO 1 SIDE
---	------	--

Comments: