

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235733
Address: 209 SE GREEN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Robb Popp	Failed	Tuesday, October 15, 2024

Informational:	
1	Misc
	Perimeter footiing
	-Complete
	-Art wall bump outs complete
	Interior pier pds
	-Complete
	Interior footings
	-Complete
	Canopy piers
	-Complete
	Courtyard retaining wall footings
	-Complete
	-Planter cascade seating walls (3) of (3)
	-Planters at seating area
	-complete
	Transformer pad enclosure
	-Complete
	-
Corrective Action Required:	
2	Miscellaneous
	Correction
	*Steps at clock tower
	-Provide proper clearance to earth and forms
	-Ensure all rebar is tied together

Comments: