

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242331
Address: 1620 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, October 15, 2024

Corrective Action Required:

1	Misc	Uncover all items for inspection still need to be uncovered
		-fireblock hvac chase to ceiling space at owners entry
		-add missing stud at hvac chase at owners entry
		-provide future vent for basement bath

Comments: