



Lee's Summit Missouri Fire Department

Office of the Fire Marshal



Alarm Test Result

Inspected by
Robert D McQueen

Completed at
10/10/2024 10:55:16

Business Name

--

Address

1950 SE BLUE
PKWY

Suite

--

City

LEE'S SUMMIT

State

MO

Zip

64063

Inspection Number

LSFD-INS-2024-0001641

Alarm:

ITEM: Company Doing Work

RESULT: Soteria.

✓ Pass

ITEM: Breaker Labeled FACP

✓ Pass

ITEM: FACP Labeled With Panel # and Breaker #

✓ Pass

ITEM: 2-Phone Lines to FACP or Cell

✓ Pass

ITEM: Smoke Detection / Alarm Activation

✓ Pass

ITEM: Heat Detection Activation

✓ Pass

ITEM: Pull Station / Alarm Activation

✓ Pass

ITEM: Interior Notification Devices / Activated

✓ Pass

ITEM: Strobe Notification Only in Restroom(s)

✓ Pass

ITEM: Horn & Strobe Notification Both Terminate on SILENCE at FACP

✓ Pass

ITEM: D/C (battery) Power Alarm Activation

✓ Pass

ITEM: Dial-In Dispatch

✓ Pass

ITEM: Correct Address Reported to Comm. Center

✓ Pass

ITEM: All System Devices Addressed/Identified at FACP

Sprinkler System Components :

✓ Pass

ITEM: Water Flow Alarm (60 sec)

✓ Pass

ITEM: Outside Horn/Strobe Activated (water flow only)

✓ Pass

ITEM: Tamper Valves (Supervisory)

✓ Pass

ITEM: Low Air Alarm

RTU Duct Detection :

✓ Pass

ITEM: Duct Detection (Supervisory)

✓ Pass

ITEM: HVAC Shut Down


Test Results :

ITEM: Test Results

RESULT: Pass

Inspection Signatures

Occupancy Contact Signature



Nikita Wright
Nwright@stacoelectric.com

Inspector Signature



Robert D McQueen
--
Engineer
816-334-8770
Rob.McQueen@cityofls.net