

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242294
Address: 1609 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Wednesday, October 16, 2024

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- address over bored stud on bearing wall at electrical panel-fire block kitchen dead space to ceiling space (height change, fire block at lower top plate)- Secure CSST at fireplace- Seal gaps south wall around soffit basement (see SW corner)- Fire block top plate above windows in basement (seal gaps) |
|---|------|---|

Comments: