

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242368  
Address: 1629 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Wednesday, October 16, 2024

Corrective Action Required:

1	Misc	-fire block hvac chase to ceiling space in garage -4 2x4 at bed 5 entry to plans -fire block kitchen/garage wall to ceiling space --address holes drilled to close to one another in floor joists above sub panel in basement
---	------	--

Comments: