

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241515
Address: 1605 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, October 16, 2024

Corrective Action Required:

1 Misc

- provide as graded plot plan
- pay all fees
- sod
- splash blocks and sump pump discharge to extend 36" from foundation
- uncover covered water meter
- identify sewer tracer wire
- label electrical panel
- open electrical in garage
- bond gas line
- support gas line to table G2424.1 of the 2018 IRC

Comments: