

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235113

Address: 2740 NE HAGAN RD, Unit:A, LEES SUMMIT, MO 64064 2740 NE HAGAN RD, Unit:B, LEES SUMMIT,  
MO 64064 2740 NE HAGAN RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Khanh Nguyen	Failed	Wednesday, October 16, 2024

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. PARTIAL EROSION CONTROL INSTALLED ALONG THE ROAD, BUT THE REST OF THE EROSION CONTROL WILL BE INSTALLED NEXT WEEK AFTER COMPLETION OF STORM WATER BASIN
---	---------------------------------------	---

**Comments:**