

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244826

Address: 1421 SW WINTHROP TER, LEES SUMMIT, MO 64081
1419 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Kyle Beard	Passed	Wednesday, October 16, 2024

Informational:

2	Miscellaneous Correction	Field verified garage foundation wall is 12 inches thick and the other interior foundation wall is 8 inches thick
---	--------------------------	---

Comments: