## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20244827

Address: 1415 SW WINTHROP TER, LEES SUMMIT, MO 640811413 SW WINTHROP TER, LEES SUMMIT, MO

64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Footing Inspection - Residential Kyle Beard Passed Wednesday, October

16, 2024

Informational:

2 Miscellaneous Field verified garage foundation wall is 12 inches thick and the other interior

Correction foundation wall is 8 inches thick

Comments: