

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241491
Address: 4005 NE APPLE GROVE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Thursday, October 17, 2024

Corrective Action Required:

1	Misc	-Complete installing fireplace **Provide min 1" clearance to combustibile. Fb fireplace space from left soffit
---	------	--

Comments: