CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225614

Address: 4101 NE PORT DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Water Line - Construction Nick Scott Passed Thursday, October 17,

Inspection 2024

Informational:

1 Misc 4-23-22 NS Site visited they tied into the water main. They put a valve and a

kicker I asked them to put more kickers since there is 2 90 degree bends and when I walked up while they where filling in the hole I did not see them.
4-24-23 NS Site visited I asked the Forman if he had put those kickers in that I asked and he said yes. I asked if he had pictures and he said no and will be

re-digging up the hole so I have verification.

6-6-23 NS Site visited and we took the first water test. They did dig up to

show me that they poured kickers at the 90 degree angles.

6-8-23 NS Site visited and I got a email saying there first water test passed.

10-17-24 NS Water test passed

Comments: