

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20241190
Address: 2134 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Failed - Stop Work	Thursday, October 17, 2024

Informational

1	Miscellaneous Correction	Full erosion control measures are in place and must be maintained until CofO
---	--------------------------	--

Corrective Action Required

2	DCM3 ESC REQUIRED 2 DAY	10-14-24 Dustin A, EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. silt fence is down in areas
---	-------------------------	---

10-17-24 Dustin A, Not corrected and gutter splashes stacked on ADA ramp

Comments: