

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241065  
Address: 3730 SW KNOXVILLE CT, LEES SUMMIT, MO 640823728 SW KNOXVILLE CT, LEES SUMMIT, MO  
64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Plot Plan Inspection</b>	Kyle Beard	Passed	Thursday, October 17, 2024

Corrective Action Required:

1	Miscellaneous Correction	A retaining wall has been built along the properties west side and is not in the original plot plan approved by the city.
---	--------------------------	---

Update plot plan with an as built and submit to the city for approval

**Comments:**