

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225614
Address: 4101 NE PORT DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Engineering	Nick Scott	Temporary C of O	Thursday, October 17, 2024

Corrective Action Required:

1	Misc	10-17-24 NS TCO Check List -Sidewalk is cracked in one spot on the Southwest corner. -clean sidewalk off -put vegetation around property and detention basin -put water meter urt outside of the building in closed in a box hanging on the wall with extra cable in the box. - I will come back next time it rains to check detention basin and make sure it drains with in 40 hours after it rains
---	------	---

Comments: