CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE PROSECUTED

Permit #: PRRES20242187

Address: 1613 SW ARBORWAY TER, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection: Outcome: Date:

Erosion Control Dustin Agcopra Failed - Stop Work Thursday, October 17, 2024

Corrective Action Required

1 Misc - REMOVE TRASH AND DEBRIS FROM LOT

Corrective Action Required

2 DCM3 ESC REQUIRED 2 10-14-24 Dustin A, Straw waddle has been damaged or

DAY removed in spots and needs to be fixed. EROSION CONTROL

REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE

WITHIN TWO BUSINESS DAYS.

10-17-24 Dustin A, has not been corrected

Comments: