

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242294  
Address: 1609 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, October 17, 2024

Corrective Action Required:

1	Misc	-fire block kitchen dead space to ceiling space ( height change, fire block at lower top plate) - Secure CSST at fireplace - Fire block top plate above windows in basement (seal gaps)
---	------	---

**Comments:**