



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113810, Building Permit - Commercial
Address: 117 SE M 291 HWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	Mike Copeland	Failed	Friday, October 21, 2011

Corrective Action Required
1 MISC

1. PAINT EXTERIOR GAS PIPING FOR CORROSION PROTECTION.

2. ANCHOR GAS PIPE TO FLOOR AT COOKING STATION.

WILL CHECK AT FINAL INSPECTION.

Gas Service Inspection - Commercial	Mike Copeland	Passed	Friday, October 21, 2011
--	---------------	--------	--------------------------

Comments: SERVICE RELEASED. 15 POUNDS HELD 10 MIN.