## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **STOP WORK ORDER**

## ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE PROSECUTED

Permit #: PRRES20242428

Address: 3116 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection: Outcome: Date:

**Erosion Control** Failed - Stop Work Thursday, October 17, 2024

Corrective Action Required

1 DCM2 ESC DEFICIENT INSTALLATION

DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.

Repair down silt fence

Maintain overgrown vegetation

10-14-24 Dustin A, Still not fixed

10-17-24 Dustin A, not corrected and there is gravel in rd

**Comments:**