



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20113727, Building Permit - Commercial  
Address: 2741 NE MCBAIN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection - Commercial</b>	Khanh Nguyen	Partial	Friday, October 21, 2011

**Comments:**  
REROUTE OF PEX WATER SERVICE LINE AROUND NEW ADDITION