

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRRES20110739, Building Permit - Residential Address: 101 SW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Pool Steel/Bonding - Mark Harding Passed Friday, October 21, 2011

Residential

Pool Final - Mark Harding Failed Friday, October 21, 2011

Residential

Corrective Action Required

2 E4103.1.1 Location POOL EQUIPMENT LOCATION AND CLEARANCES.

PROVIDE 15-20 AMP OUTLET WITHIN 20FT OF POOL (GFCI)
2. PROVIDE GAS PRESSURE TEST ON GAS LINE INSTALLED TO

POOL HEATER.

NO INSPECTION ON GAS LINE.

POOL HEATER WAS NOT ADDED TO PERMIT. CHECK ELECTRICAL WHERE TIES INTO HOUSE.

Comments: