

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244922  
Address: 3205 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:            | Inspector:     | Outcome: | Date:                      |
|------------------------|----------------|----------|----------------------------|
| <b>Erosion Control</b> | Dustin Agcopra | Failed   | Thursday, October 17, 2024 |

Corrective Action Required:

|   |                            |                                                                                                                                                                               |
|---|----------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | DCM3 ESC<br>REQUIRED 2 DAY | 10-17-24 Dustin A, dirt piles have pushed over Erosion control, Dirt now on SW.<br>EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. |
|---|----------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**