

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242857

Address: 1420 SW WINTHROP TER, LEES SUMMIT, MO 64081
1418 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Shawn Hoffman	Partial	Thursday, October 17, 2024

Corrective Action Required:

2	Misc	ATTIC SPACE AND RIM BOARD PARTIAL
		1418
		Fire caulk front corner mechanical room
		Fire caulk top of bedroom demise wall
		1420
		Seal gaps at roof deck

Comments: