

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241195
Address: 4359 NE HIDEAWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Ready for Temp CO	Thursday, October 17, 2024

Corrective Action Required:

1	Misc	-Final grade, sod -Support garage receptacle yokes -No power to some garage receptacles -Window located within 24" of deck door must be safety tempered glazing window -Provide AFCI protection for all outlets required per NEC 210.12. (Laundry)
---	------	--

Comments: