

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241045

Address: 1433 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1431 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Shawn Hoffman	Partial	Thursday, October 17, 2024

Corrective Action Required:

1	MISC	ATTIC SPACE AND RIM BOARD
		1431
		- Pack gap from duckwork to wall with rock wool
		1433
		- Seal gap behind furnace

**Comments:**