

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241188

Address: 1456 SW WINTHROP TER, LEES SUMMIT, MO 640811454 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Shawn Hoffman	Partial	Thursday, October 17, 2024

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	ABOVE CEILING and RIM BOARD
		1454
		-Address missing double top plate at master bedroom
		Protect rafter at back of master bedroom
		1456
		- Protect gap above master bedroom
		- Seal gap back corner of rim board

Comments: