

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241047

Address: 1450 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1448 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Shawn Hoffman	Partial	Thursday, October 17, 2024

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	ABOVE CEILING and RIM BOARD 1448 OK  1450 -Protect rafterback of master bedroom -seal gap of rim board at back of house -protect into soffit at garage doors
---	----------------------------------	--

Comments: