

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242368  
Address: 1629 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Mitchell Schwarz	Failed	Friday, October 18, 2024

Corrective Action Required:

1	Misc	Inspection denied no access concrete poured at front and rear entrance
---	------	--

- Connect ufer ground to main point of disconnect
- ufer ground connection not done properly
- bond gas line.

**Comments:**